

Utah Department of Environmental Quality

Division of Drinking Water

Monitoring Schedule

Run Date:
08/04/2011 12:17 pm

PWS ID: UTAH17027 **Name:** SWAN CREEK VILLAGE

Legal Contact: SWAN CREEK VILLAGE HOA **Rating:** Approved
SCOTT CROSBIE **Rating Date:** 02/17/2006

Address: PO BOX 13948 **Activity Status:** Active
OGDEN, UT 84412

Phone Number: 801-458-7281

City Served (Area):

County: RICH COUNTY

System Type: Non-community **Last Inv Update:** 05/27/2010 **Avg Daily Prod:**

Activity Status Cd: Active **Last Snty Srv Dt:** 09/11/2008 **Total Dsgn Cap:**

Population: 25 **Surveyor:** DAVID F HANSEN **Total Emerg Cap:**

Oper Period: 6/1 to 9/30

Gal/Day Gal/Min

Total Coliform Rule Monitoring

| Sample Count | Sample Type | Sample Frequency | Effective Begin Date | Effective End Date | Seasonal Start | Seasonal End | Analyte Name |
|--------------|-------------|------------------|----------------------|--------------------|----------------|--------------|----------------|
| 1 | Routine | Quarterly | 07/01/2009 | | 6/1 | 9/30 | COLIFORM (TCR) |

Additional Monitoring Requirements

(The Sample Label is not correct for Disinfection Byproducts, TOC, TOC Alkalinity, and any triggered groundwater samples)

Facility ☐ ID Facility Name

| Analyte Name | | Sample Count | Sample Type | Sample Frequency | Last Sample | Next Sample Between |
|--------------|-------------------------------------|--------------|-------------|--------------------|-------------------------|-----------------------|
| SS977 | GROUP SOURCE SAMPLING STATION SS977 | | | Activity Status: A | Sample Label: UTAH17027 | SS977 SS977 |
| | NITRATE | 1 | Routine | Year | 12/22/2010 | 01/01/2011-12/31/2011 |
| | SULFATE | 1 | Routine | 9Y | 06/18/2008 | 01/01/2011-12/31/2019 |

Sources Grouped for Sampling Compliance

Source Group ID: UTAH SAMPLING STATION SS977

Sources in Group

WS001 WELL # 3 UTAH17027 SWAN CREEK VILLAGE

WS002 COOK WELL UTAH17027 SWAN CREEK VILLAGE